



BV LCIE
CHINA
Number

N° 2066AS12WTU37646

ATTESTATION of conformity with European Directives

Product: MCCB
Reference TOS1-400 Series
Issued to WENZHOU TONGOU ELECTRICAL CO.,LTD
Address Paidong Industrial Zone,Qiligang,Yueqing City,Zhejiang province,China.
Manufacturer WENZHOU TONGOU ELECTRICAL CO.,LTD
Ue: 400V~
Utilization category: A
Ie: 225A;250A;315A;350A;400A
50/60Hz
Icu=50kA
Ics=35kA
Technical characteristics Ui= 800V
Uimp=8kV
IP40 for front cover
Pollution degree: 3
Reference temperature: 40°C
Distance for metal screen:
Back:0mm Front:10mm; Top:100mm Botton:100mm; Left:30mm
Right:30mm(values declared by client)

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-2:2017+A1:2020; EN 60947-1:2007 + A1:2011 + A2:2014	B200082	2020-11-23

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), December 9th, 2020.

Charlie CHEN
Product Line Manager



..... be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com

Version 3/2016.02.19