



BV LCIE  
CHINA  
Number

N° 2266AS11WTU47398

## ATTESTATION of conformity with European Directives

*Product:* RCBO  
*Reference:* TOBNS-40  
*Issued to:* WENZHOU TONGOU ELECTRICAL CO.,LTD  
*Address:* Paidong Industrial Zone, Qiligang, Yueqing City, Zhejiang province, China.  
*Manufacturer:* WENZHOU TONGOU ELECTRICAL CO.,LTD  
*Technical characteristics:* Type C and B  
1P+N  
A Type and AC Type  
Ue=110-240V, 230V~ and 240V~ (1P+N)  
In=40A;32A;25A;20A;16A;10A;6A  
Icn= 6000A  
Ics= 6000A  
In=10mA;30mA  
Energy limit class: 3 (according to EN 61009-1)  
Im=3000A  
Grid distance: 50mm  
Uimp=4kV  
Ui=415V  
50/60Hz

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 61009-1:2012+A1:2014+A2:2014+A11:2015+A12:2016	B220105	14/10/2022

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), November 7<sup>th</sup>, 2022.

Charlie CHEN  
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)