



A P P R O V A L S ®

Certificate of Conformity/Approval

Certificate No.: SAA-212802-EA

Certificate Holder: Wenzhou Tongou Electrical Co., Ltd
Paidong Industrial Zone, Qiligang, Yueqing City,
Zhejiang Province
P.R. China

Regulatory Definition: Residual Current Device
Product Description: RCBO
Trade Name/s: tongou
Model No.: TOBNS-40
Rating/Marking/s: Ue=230/240V~(1P+N), 50/60Hz
In=6, 10, 16, 20, 25, 32, 40A, Type B & C
IΔn=10, 30mA, Type A & AC
IΔm=3000A
Icn= Ics=6000A

Standard/s: AS/NZS 61009.1:2015
Condition/s: Nil

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA-212802-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 26 January 2022
Expiry Date: 26 January 2027

R. A. Nill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 26-01-22 212802
Page 1 of 1